



Technical Datasheet

#### Application

The WGT fits independent from pipe manufacturer as a sealing element for all listed sizes. The WGT seal off water and gas in micro ducts with various cable diameters and works also like a blind plug. The slotted version suits in case of no access to end of cable or if cable was already spliced (i.e. maintenance). Beside excellent sealing performance the WGT also has good strain relief for cable and micro duct. With the optional PowerClip the strain relief improve by clamping the strength members like aramid yarn. At the cable side the WGT has an integrated shape for bend protection. Size 5-12 comes with a filler clip for mechanical support of slot in WGT body.


Please also refer to the technical data sheets for the products.



#### Scope of delivery

Every WGT housing comes with a sealing gasket according to the selected cable size. Slotted version comes with a slotted sealing gasket. Sealing gasket with blind plug from shut version fit also in slotted version. To use them as slotted version, cut sealing gasket in longitudinal direction.

**Note:** Size 5-12 comes with a filler clip (red plastic part)




#### Sealing gaskets

Various sealing gaskets for different micro ducts and applicable cable diameters are available. Please refer to the table with available sizes on last page. Customer specific gaskets are available on request.



#### PowerClip®

If fixation of strain relief elements of the cable is required, the PowerClip® is the right choice.



#### Tools

For every size of WGT a disassembly clip is available. For most sizes also a professional installation tool is available. The tool simplifies assembly and disassembly of the WGT especially if the cable is already in place. The WGT can be installed without using the tool but for disassembly, at least for WGT size 5mm, 7mm and thin cables, the use of the PullClip is strongly recommended.




PullClip	Order No.	Assembly Pliers	Order No.	PowerClip®	Order No.
WGT 5mm	01-044-01 A			-	-
WGT 7mm	01-045-01 A	WGT 7mm	01-038-01 A	WGT 7mm-	01-011-01-A
WGT 10mm	01-046-01 A	WGT 10mm	01-039-01 A	WGT 10mm	01-008-01 A
WGT 12mm	01-047-01 A	WGT 12mm	01-040-01 A	WGT 12mm	01-009-01 A
WGT 14mm	01-048-01 A	-	-	-	-
WGT 16mm	01-049-01 A	-	-	-	-

## 1. Important instructions

The manual is for the slotted version of WGT, separated into the parts assembly with and without tools.


- Before starting installation, check if the end of the micro duct is clean of any kind of dirt pollution and lubricants. Also check carefully inside of micro duct on such contamination to avoid application problems later.
- The end of a micro duct need a straight, vertical, clean cut with a tool recommended by duct manufacture.
- Due to tolerances of the outside diameter of micro duct, different force may appear for installing the WGT body onto the duct.

### 1. Installation of slotted WGT without tools for micro duct with cable




1.1 Slotted version comes with a slotted sealing gasket.


**Note:** Size 5-12 comes with a filler clip (red plastic part)




1.2 Place seal with cone side towards micro duct around cable and slide it till stop into the micro duct.




1.3 Place filler clip (size 5-12) on top of sealing gasket and hold it with your thumb against micro duct.



1.4 Slide WGT body onto the filler clip (size 5-12) and then push it on the micro duct.




1.5 Push WGT on the micro duct until the edge of the duct is at least flush with the ring marking on WGT body (arrows). This ensures the tightness.



**Note:** To improve tightness and tensile strength on micro duct, rotate WGT ¼ turn clockwise.

**1.6 Disassembly of WGT without tools for a micro duct with cable**




1.6 Release WGT by turning it counterclockwise but hold cable during procedure.

If sealing gasket is clean and in good condition it may be used again.


**Note:** : If WGT 5/7mm and thin cables are used, usage of dismounting tool is strongly recommended.

**2. Installation of WGT with assembly pliers for micro duct with cable**

Installation and mainly disassembly is much faster and gentle for the cable.




**Note:** Always press release lever during installation or disassembly.




2.1 Install WGT and sealing gasket till chapter 1.3.




2.2 Slide WGT body onto the filler clip (size 5-12) and then push WGT body **just slightly** on the micro duct.



2.3 Open assembly pliers by pushing opening lever.



2.4 Put WGT into assembly pliers and close it. Cable has to point out top side of tool micro duct to bottom side. If it doesn't close perfect, WGT was inserted faulty.




2.5 Press release lever and push WGT onto micro duct.

**WGT must be in position like described in point 1.5**

### 3. Disassembly of WGT with tools for a micro duct with cable




3.1 Put WGT into assembly pliers and close it. Cable has to point out top side of tool, micro duct has to point out to bottom side. If it doesn't close perfect, WGT was inserted faulty.




3.2 Press release lever and remove the WGT from the micro tube. Open the assembly tool and remove the WGT. If sealing gasket is clean and in good condition it may be used again.


### 3.3 Disassembly of WGT with PullClip for a micro duct with cable



3.4 Slide PullClip on the micro duct behind WGT. The cone-shaped notch must point towards WGT.





3.5 Place one finger left and another finger on right side under the PullClip, fix top side of WGT with your thumb and pull off WGT from micro tube.



**Note:** If sealing gasket is clean and in good condition it may be used again.

**4. Installation of WGT with PowerClip to clamp strain relief (aramid) of cable**


If fixation of strain relief elements of the cable is required, PowerClip has to be installed




**Note:** Size 5-12 comes with a filler clip (red plastic part)




4.1 Install sealing gasket like in capture 1.2. To facilitate mounting of WGT, untie strength members (aramid yarn) after installation of WGT




4.2 Strip cable jacket according to specification of cable manufacturer. After installation of WGT, edge of cable jacket must be flush with edge of WGT body. Lines in picture shows length of cable jacket to be cut. Leave at least 25 cm of aramid yarn for PowerClip installation




4.3 Install WGT with or without tool like described in the previous chapters. Push WGT on the micro duct until the edge of the duct is at least flush with the ring marking on WGT body (arrows). This ensures the tightness.




**Note:** To improve tightness and tensile strength on micro duct, rotate WGT ¼ turn clockwise. Pull aramid yarn tight and slightly twist or twirl it.




4.4 Mount PowerClip **opposite side** of slot onto the WGT in a way all 3 tabs inside of the clip fit into the holes of the WGT body.




4.5 Wrap aramid yarn in a figure 8 shape under the flaps of the PowerClip. Pull aramid yarn tight, twist and pull into direction towards micro duct and beneath flap of PowerClip.



4.8 Repeat this figure 8 shape wrap up to 6 times. If possible, remain enough length of aramid yarn to enable a retry of installation.



4.6 Pull aramid yarn diagonally, up to the side of the cable. Then slide it beneath flap of PowerClip back into direction of the micro tube.



4.7 Again pull aramid yarn diagonally, upwards beneath PowerClip like described before.

## 8. Installation LabelClip

The LabelClip is available for micro ducts with outer diameters of 7/10/12/14/16/20mm (<https://www.elitex-gmbh.de/werkzeuge-zubehoer-en/beschriftungsclip-en/>)



Item	Order No
LabelClip for WGT 7mm	01-061-01 A
LabelClip for WGT 10mm	01-062-01 A
LabelClip for WGT 12mm	01-063-01 A
LabelClip for WGT 14mm	01-064-01 A
LabelClip for WGT 16mm	01-065-01 A
LabelClip for WGT 20mm	01-066-01 A

8.1 Position the LabelClip right below WGT and clip it onto micro duct. The LabelClip is rewriteable multiple times with permanent marker. Labels from common label printers stick well to the LabelClip and still can be removed.

Table sealing gaskets

micro duct dia.	sealing gasket																															
	min	cable	max	gasket no.	min	cable	max	gasket no.	min	cable	max	gasket no.	min	cable	max	gasket no.	min	cable	max	gasket no.	min	cable	max	gasket no.	min	cable	max	gasket no.				
5mm																																
5x1= inner 3.0	0,9	-	1,5	1	1,4	-	2	2	1,9	-	2,5	3																				
5x0.75= inner 3.5	0,9	-	1,5	1	1,4	-	2	2	1,9	-	2,5	3	2,4	-	3	4																
7mm																																
7x1.50= inner 3.0	1	-	1,6	5	1,5	-	2,1	6	2	-	2,6	7	2,5	-	3,1	8																
7x0.75= inner 5.5	1	-	1,6	5	1,5	-	2,1	6	2	-	2,6	7	2,5	-	3,1	8	3	-	3,6	9	3,5	-	4,1	10								
10mm																																
10x2.0= inner 6.0	2	-	3	12	2,9	-	3,9	13	3,8	-	4,8	14	4,7	-	5,7	15																
10x1.0= inner 8.0	2	-	3	12	2,9	-	3,9	13	3,8	-	4,8	14	4,7	-	5,7	15	5,6	-	6,6	16												
12mm																																
12x2.0= inner 8.0	2	-	3	12	2,9	-	3,9	13	3,8	-	4,8	14	4,7	-	5,7	15	5,6	-	6,6	16												
12x1.1= inner 9.8	2	-	3	17	2,9	-	3,9	18	3,8	-	4,8	19	4,7	-	5,7	20	5,6	-	6,6	21	6,5	-	7,5	22								
14mm																																
14x2.0= inner 10.0	6	-	7	24	6,9	-	7,9	25	7,8	-	8,8	26																				
14x1.3= inner 11.4	6	-	7	24	6,9	-	7,9	25	7,8	-	8,8	26	8,7	-	9,7	27																
16mm																																
16x2.0= inner 12.0	6	-	7	24	8	-	9	28	8,9	-	9,9	29	9,8	-	11	30																
20mm																																
20x2.5= inner 15.0	8	-	9	31	8,9	-	9,9	32	9,8	-	11	33	11	-	12	34	12	-	13	35±												
20x2.0= inner 16.0	8	-	9	31	8,9	-	9,9	32	9,8	-	11	33	11	-	12	34	12	-	13	35±	13	-	14	37±	14	-	15	38±				

\*Number for sealing gasket will be reassigned

### Elitex GmbH

Justus-von-Liebig-Straße 13  
D-85247 Schwabhausen  
Mail: office@elitex-gmbh.de  
www.elitex-gmbh.de

Elitex GmbH and its affiliates referenced herein have made every reasonable effort to ensure the accuracy of the information contained in this instruction. Elitex GmbH cannot assure that this information is free of errors. For this reason, Elitex GmbH doesn't make any representation or offer any guarantee that such information is accurate, correct, reliable or current. Elitex GmbH reserves the right to make any adjustments to the information at any time. Elitex GmbH expressly disclaims any implied warranty regarding the information contained herein, including, but not limited to, the implied warranties of merchantability or fitness for a particular purpose. Elitex GmbH only obligations are those stated in Elitex GmbH specifications, standard terms and conditions of sale. Elitex GmbH will be in no case liable for any incidental, indirect or consequential damages arising from or in connection with, including, but not limited to, the sale, resale, use or misuse of its products. Users should rely on their own judgment to evaluate the suitability of a product for a certain purpose and test each product for its intended application  
Product and System patented for Elitex GmbH. © Copyright Elitex GmbH 2021

Version 1.5